

KCSD Lead Sampling 2020

Facility	Location	Result (ug/L)
Jr / Sr High School	Maintenance Sink	<1.00
Jr / Sr High School	District Office	<1.00
Jr / Sr High School	District Office Fountain	1.05
Jr / Sr High School	HS Soup Kettle	1.58
Jr / Sr High School	HS Kitchen Prep Sink	<1.00
Jr / Sr High School	Athletic Bottle Filler	<1.00
Jr / Sr High School	Athletic Training	2.75
Jr / Sr High School	Jr. High Fountain	1.02
Jr / Sr High School	Science Rm 204	5.32
Jr / Sr High School	Nurse's Suite Bottle Filler	<1.00
Jr / Sr High School	Home Ec Sink	7.83
Jr / Sr High School	Band Rm Fountain	1.3
Jr / Sr High School	TC Academy Sink	10.9
Jr / Sr High School	Teacher's Lounge Sink	6.5
Jr / Sr High School	HS Locker Rm Bottle Filler	<1.00

KCSD Lead Sampling 2020

Facility	Location	Result (ug/L)
Sugar Creek Elementary	Primary Wing Bottle Filler	<1.00
Sugar Creek Elementary	Nurse's Sink	<1.00
Sugar Creek Elementary	Boy's RR Fountain	<1.00
Sugar Creek Elementary	Girl's RR Fountain	<1.00
Sugar Creek Elementary	Gym Bottle Filler	<1.00
Sugar Creek Elementary	Kitchen Soup Kettle	<1.00
Sugar Creek Elementary	Kitchen Sink	1.28

KCSD Lead Sampling 2020

Facility	Location	Result (ug/L)
Chicora Elementary	Nurse's Sink	2.28
Chicora Elementary	Library Bottle Filler	<1.00
Chicora Elementary	209 Bottle filler	<1.00
Chicora Elementary	209 Fountain	<1.00
Chicora Elementary	Secondary Bottle Filler	<1.00
Chicora Elementary	Kindergarten Girl's RR	2.87
Chicora Elementary	Faculty Lounge	1.13
Chicora Elementary	Gym Bottle Filler	<1.00
Chicora Elementary	Kitchen Sink	2.59
Chicora Elementary	Soup Kettle	34.7